No. C452/19

NOTARIAL REGISTER SI. No...5. 3774 Recipt No.... Station Officer, Date 14-2-2022

Fire & Rescue Station, Kottayam.

Manager,

Sree Kumaramangalam Public School, Kumarakom, Kottayam.

Sir,

Sub: Fire & Rescue Station, Kottayam - Application for Final NOC rejection reg.

Ref: 1) Application from Sree Kumaramangalam Public School, Kumarakom, Kottayam.

- 2) GO(p) No. 82/2017/LDGD dated: 31/10/2017.
- 3) Kerala Panchayat Building Construction Act.

Sree Kumaramangalam Public School, established in 2003, in Kottayam Taluk, Kottayam District, Re-Survey No. 51,52,54 building No. 14/716, 14/717 has applied for the final NOC. But after verifying the documents, it is found that this three storeyed educational institution has 11.10 mts height and has an area of 474 sq.m.

But according to ref No. (2), (3), the educational institution which has more than 15m height or more than 1000 sq.m area should only apply for the Fire NOC. The building which have less than 15m height / the area between 1000 sq.m. - 300 sq.m should only acquire the declaration regarding Fire and Safety from the Architect / Engineer of the building concerned. The owner of the building should give a self declaration regarding the Fire and Safety and verified it annually.

As per your application, it is found that your educational institution comes under ref (2), ie, an area below 1000 sq.m/ height below 15m. As your school doesn't need Fire NOC, we are hereby returning all the documents and application submitted by you.

> K.A. PRASAD B.Sc., LL.B. **ADVOCATE & NOTARY** Reg. No. 05/2000/KTM Kallil Buildings **Near North Gate of Collectorate** Kottayam- 686 002, Kerala, India Mob: 9447306844

Yours faithfully, Sd/ Station Officer. Fire & Rescue Station,

Fire & Rescue Station

Ph: 0481 2567444

Date: 04/07/2019

Kottayam. Pin: 686001

Kottayam. Pin: 686001 y that this is the true and connect

tron 2 the certificate No - C. 452/19

Seal

English version

4/2/2019 Of ire and Resource Station Kollayon Principa

Manage



